

SARNET: SEVERE ACCIDENT RESEARCH NETWORK OF EXCELLENCE

Thierry ALBIOL, *Institut de Radioprotection et de Sûreté Nucléaire, IRSN/DPAM/DIR –
Bat 245, BP3, 13115 St Paul Lez Durance Cedex, France, thierry.albiol@irsn.fr*

Tim HASTE, *PSI, Switzerland, tim.haste@psi.ch*

Jean-Pierre VAN DORSSELAERE, *IRSN, France, jean-pierre.van-dorsselaere@irsn.fr*

Jean-Michel BONNET, *CEA, France, jean-michel.bonnet@cea.fr*

Leonhard MEYER, *FZK, Germany, leonhard.meyer@iket.fzk.de*

Bernard CHAUMONT, *IRSN, France, Bernard.chaumont@irsn.fr*

Bal Raj SEHGAL, *KTH, Sweden, bsehg@safty.sci.kth.se*

Klaus TRAMBAUER, *GRS, Germany, trb@grs.de*

David BERAHA, *GRS, Germany, bea@grs.de*

Alessandro ANNUNZIATO, *JRC-ISPRA, Italy, alessandro.annunziato@jrc.it*

Bernard ADROGUER, *IRSN, France, bernard.adroguer@irsn.fr*

Jean-Claude MICAELLI, *IRSN, France, jean-claude.micaelli@irsn.fr*

Ivo KLJENAK, *JSI, Slovenia, Ivo.Kljenak@ijs.si*

Keywords: Severe Accident, SARNET, Network of Excellence.

ABSTRACT

51 organizations network in *SARNET* (Severe Accident Research NETwork of Excellence) their capacities of research in order to resolve the most important remaining uncertainties for enhancing, in regard of Severe Accidents (SA), the safety of existing and future Nuclear Power Plants (NPPs). This project, co-funded by the European Commission (EC), has been defined in order to optimise the use of the available means and to constitute sustainable research groups in the European Union. SARNET tackles the fragmentation that exists between the different R&D national programmes, in defining common research programmes and developing common computer tools and methodologies for safety assessment. SARNET comprises most of the actors involved in SA research in Europe (plus Canada).

To reach these objectives, all the organizations networked in SARNET contribute to a so-called Joint Programme of Activities (JPA), which consists in:

- Implementing an advanced communication tool for accessing all project information, fostering exchange of information, and managing documents;
- Harmonizing and re-orienting the research programmes;
- Jointly analysing the experimental results provided by research programmes in order to elaborate a common understanding of relevant phenomena;

- Developing the ASTEC code (integral computer code used to predict the NPP behaviour during a postulated SA), which capitalizes in terms of physical models the knowledge produced within SARNET;

- Developing Scientific Databases, in which all the results of research programmes are stored in a common format (DATANET);
- Developing a common methodology for Probabilistic Safety Assessment (PSA) of NPPs;
- Developing courses and writing a text book on SA for students and researchers;
- Promoting personnel mobility between various European organizations.

After the first period (2004-2008), co-funded by the EC, the network will progressively evolve toward self-sustainability. The bases for such an evolution, still under discussion, are presented in the last part of the paper.

1. BACKGROUND

The current Nuclear Power Plants (NPPs) existing in Europe are designed with the principles of defence in depth. In particular, they incorporate a strong containment and engineering systems to protect the public against radioactivity release for a series of postulated accidents. In some low probability circumstances, some severe accident sequences may result in core melting and plant damage leading to dispersal of radioactive material into the

environment and thus constituting a health hazard to the public (Fig. 1).




Fig. 1: Schematic severe accident on a NPP

Remarkable achievements have been obtained in the field of Water Reactor SA, thanks in particular to the numerous European actions undertaken within the 4th and 5th Framework Programmes (FP) of the European Commission. In spite of the accomplishments reached, a limited number of specific issues remain where research activities are still necessary in order to reduce further uncertainties that are considered of importance and to consolidate severe accident management plans: core reflooding, iodine chemistry, ex-vessel melt coolability, timing of base-mat failure are examples of remaining issues underlined by the Phenomena Identification and Ranking Table (PIRT) action conducted within the EURSAFE thematic network of the 5th FP (Magallon, 2005).

The best state of knowledge on severe accident phenomenology, qualified computer tools and appropriate methodology should be used uniformly throughout Europe – and ideally, worldwide - in order to evaluate the corresponding risks and update former evaluations, taking into account notably the inevitable evolutions in reactor operations (e.g. new type of fuels, higher burn-up, extension of plant life). Additional appropriate engineering devices and/or accident management measures may have then to be developed and implemented in order to reduce the risks to an acceptably low level.

Up to now, research programmes on Severe Accidents are usually decided at national levels. Co-operation agreements are often concluded around these national programmes, but on a case by case basis. Facing the inevitable reduction of the national budgets in this field, it is necessary to coordinate better the national efforts to optimise the use of the available expertise and experimental facilities in order to resolve the remaining issues. This coordination will take benefits of, and strengthen, the existing complementarities between the different laboratories throughout Europe (corium / fission product chemistry experts, small scale / large scale testing, simulants/real materials, experimentalists / model developers / code developers).

Therefore, a number of European R&D organizations, including technical supports of safety authorities, industries, utilities and universities, have decided to seize the opportunity offered by the European Commission in the framework of the 6th Framework Programme to network in SARNET (Severe Accident Research NETwork of Excellence) their capacities of research in the severe accident area in a durable way in order to resolve outstanding issues for enhancing the safety of existing and future NPPs.

The general objectives of SARNET are to:

- Tackle the fragmentation that exists between the different R&D organizations, notably in defining research programmes and developing/qualifying computer tools;
- Harmonize the methodologies applied for assessing risk and improve Level 2 PSA tools;
- Diffuse the knowledge to Newcomers to the European Union more efficiently and associate them with the definition and the conduct of our research programmes more closely;
- Bring together top scientists in severe accident research to constitute a world leadership in advanced computer tools for severe accident risk assessment.

In overall 51 organizations are now in the project, coming from 18 Member States of the European Union (Austria, Belgium, Bulgaria, Czech Republic, Finland, France, Germany, Greece, Hungary, Italy, Lithuania, the Netherlands, Romania, Slovakia, Slovenia, Spain, Sweden, United Kingdom), Switzerland, Canada and the Joint Research Centres of the European Commission (Fig. 2). The network started its activity on April 1st, 2004 for a four-year period (duration of the contract with the European Commission) and is coordinated by IRSN (Micaelli, 2005). Then, the network will progressively evolve toward self-sustainability. The bases for such an evolution, still under discussion, are presented in the last part of the paper.




Fig 2. SARNET organization countries

2. ORGANIZATION

The SARNET Network is organised on the basis of a two-level structure. On the first level, a Governing Board involving all members is in charge of strategic decisions and is advised by an Advisory Committee and an Ad-hoc Scientific Committee. On the second level, a Management Team is entrusted with the task of the day-to-day management of the Network.

2.1 The Governing Board

SARNET is steered by a Governing Board. It reviews the progress made by the Network, in particular in terms of progressive integration, and makes recommendations on future orientations. It decides upon the allocation of the financial contribution of the European Commission and approves the activity programme. The Governing Board is composed of:

- 1 member designated by each Contractor;
- 1 representative of the Commission as observer.

Members are in general of high management level and may commit the resources of their organization for performing activities decided by the Governing Board.

2.2 The Advisory Committee and the ad-hoc Review Committee

The role of the Advisory Committee is to provide the Governing Board with advice on strategic orientations of the research activities of SARNET. It involves managers of end-user organizations, including Vendors, Utilities and Regulatory Bodies, appointed by the Governing Board. The role of the Ad-hoc Scientific Review Committee is to review, on behalf and at the request of the Governing Board, the scientific and technical activities performed by SARNET and the knowledge acquired.

2.3 The Management Team

The Management Team is in charge, on behalf of the Governing Board, of the day-to-day administration of SARNET.

Based on the general SARNET organization, the Management Team is composed of the SARNET Coordinator heading the Team, of the Advanced Communication Tool Leader, of the ASTEC code Coordinator, of the PSA2 Leader, of the Experimental Database Leader, of the Severe Accident Research Priorities Leader, of the three Scientific Coordinators (corium, containment and source term domains), of the Excellence Spreading Coordinator (Education and Training, Book and Mobility work-packages) and of a Secretary.

The Management Team monitors notably the progress made in the different activities, examines any difficulty which may arise and examines with the corresponding project leaders the possible actions to overcome them, examines the new projects, promotes collaborations both within the Network and with external organizations (OECD, ISTC, AIEA, etc), makes proposals to the Governing Board for updating the programme of activity, manages the communication system and the databases of the Network, organises the training and education activities, and disseminates information inside and outside the network, in particular by organizing periodic

conferences and topical seminars, and by setting up a public Web site.

The Coordinator acts under the control of the Governing Board, and reports to it on his duty. He provides the Governing Board with technical and financial reports and implements its decisions, notably by updating the programme of activity. He is furthermore responsible for the relations with the European Commission, which, yearly, organises a review of the progress of the project by a panel of independent experts.

3. THE JOINT PROGRAMME OF ACTIVITIES

To achieve the objective of SARNET a Joint Programme of Activities (JPA) has been defined. All the organizations networked in SARNET contribute to the JPA, which can be, beyond management activities, broken down into three elements (Fig. 3):

- Integrating activities to strengthen links between organizations;
- Joint research activities to resolve remaining outstanding issues;
- Spreading of excellence activities.




Fig. 3: SARNET Joint Programme of Activities

The integral code ASTEC (Van Dorsselaere, 2004), jointly developed by IRSN and GRS, is the main integrating component and contributes efficiently to the diffusion of the knowledge. Activities linked to ASTEC thus appear as “Integrating Activities”. Furthermore, most of the “Joint Research Activities” are linked to ASTEC as one of their ultimate goals is to provide physical models to be integrated in ASTEC. The exchange of information on the detailed models developed by the various experts through interpretation of experiments will lead in the medium and long term to generic common models in the different detailed codes (example of ICARE/CATHARE and ATHLET-CD for core degradation). Improved models for ASTEC itself will be derived from these and included in this common reference code.

The R&D needs are periodically updated and the objectives of future experiments are defined taking into account the outcome of the collaborative work on risk studies. A consensus could be reached on closure of some issues and would allow redistribution of competence and manpower on open ones in concert with other international projects (e.g. OECD projects).

Main achievements, which are described below, correspond to the current status of the Project after three years of operation.

4. MAIN ACHIEVEMENTS

4.1 Integrating Activities

The integrating elements of the programme are considered of highest importance and remain the key elements of the JPA.

One integrating element is the implementation of an Advanced Communication Tool (ACT) for aiding information exchange. ACT is a key concept to achieve SARNET goals; it provides unified support for efficient communication within the network, concerning:

- Access, search, publication of documents and codes (concept of knowledge storage),
- Contact and communicating with partners (interactive and collaborative services),
- Joint co-ordination of actions/programmes (co-operative management of the network),
- List of links to satellite community projects (R&D projects, related sites).

A platform has been developed and deployed. Access is given by Web Browsers, enabling access from any Internet connection. After three years, around 250 users of SARNET have been granted access to this tool and the ACT is used intensively and efficiently.

A major integrating activity is the development, assessment and maintenance of the SA integral analysis code ASTEC. Twenty-nine organizations collaborate with IRSN and GRS on the development and assessment of this code. It describes the behaviour of a whole NPP under SA conditions, including Severe Accident Management (SAM) engineering systems and procedures. It is intensively used by IRSN for Level 2 PSAs for 900 and 1300 MWe PWRs, and due to large improvements on its robustness and on its computation time, more and more partners use it for complete accident scenario calculations. It is the main integrator of knowledge in SARNET.

A close and efficient collaboration between ASTEC users and developers has been set up using ACT and the MARCUS tool for code maintenance. Several training courses were organized. Three code versions were released to the SARNET partners: V1.1 mid-04, V1.2 mid-05 and V1.3 end of 2006. Two ASTEC Users' Club meetings, held in February 05 and in June 2006, allowed fruitful direct discussion between users and developers.

Model developments are under way by CEA, in close collaboration with IRSN, on in-vessel late-phase of core degradation (already implemented in V1.3) and on vessel external cooling. Other developments proposed by the source term Topic will be implemented in 2007. Concerning other reactor types than PWRs, very few needs were identified for adaptations of the code to VVER-440 and VVER-1000: their account is underway. For BWR, RBMK and CANDU, specifications of model adaptations are under way along with exploratory calculations.

Extensive validation has also been carried out. The code has been applied to more than 35 experiments (analytical and integral ones). Generally speaking, the results were ranked as good, even very good for thermal-hydraulics, core degradation and aerosol behaviour. Partners, independent from the developers, confirmed IRSN-GRS results on several International Standard Problems (44, 45, 46, 47) and on the PHEBUS FPT0/1 tests. After some

adaptations, FZK is now using the code to prepare and analyse its experiments (QUENCH and LIVE tests). Several plant applications are also underway on various NPPs (PWR, VVER-440, VVER-1000, CANDU), including benchmarks with other codes (MELCOR, MAAP4, ...). All users' requirements on ASTEC evolution are now taken into account by IRSN and GRS for the specifications of the new series of versions ASTEC V2.

Harmonization of Level 2 PSA methodology and development of advanced tools is also an integrating activity. Level 2 PSA is a powerful tool to assess plant-specific vulnerability regarding NPP SA. It evaluates possible SA scenarios in terms of frequency, loss of containment integrity and radioactive release into the environment and quantifies the contribution of prevention and mitigation measures in terms of risk reduction. Different approaches are used in Europe, derived more or less from what has been implemented in the USA. A description and comparison of the main elements of methods used by the different partners to develop their PSA has been written. A questionnaire has been set up and the answers have been analyzed in order to define next steps of harmonization, this word having different meanings depending on the various experts. Harmonization of level 2 PSA issues is going on and feasibility case studies on hydrogen combustion, iodine chemistry and melt corium concrete interaction (MCCI) are well advanced while work has been initiated on other issues such as large early releases (LERF) and reactor end states definitions. A State of the Art Report on Dynamic Reliability methods has been produced and the limitations of classical methods, which could be exceeded using these reliability methods, were identified. Examination of the benefit of one of the possible methods (Monte Carlo Dynamic Event Tree – MCDET) has been achieved on station black out situation. A benchmark exercise to compare dynamic reliability methods with classical ones is on going. The exercise deals with hydrogen distribution and combustion issues and considers the possibilities of ignition when physically possible, core reflooding and spray system operating at any time. The specification of the exercise has been provided and results of the first step (without uncertainties assessment) are available while the second step (with uncertainties assessment) is ongoing.

The objective of DATANET, the SARNET experimental database network, is to develop and maintain an instrument that ensures preservation, exchange and processing of SA experimental data, including all related documentation. The data are both existing experimental data that SARNET partners are willing to share within the network and all new data produced within SARNET. DATANET is based on the STRESA tool developed by JRC Ispra and consists of a network with several local databases (or nodes). From the central database, it is possible to connect with other local databases; direct connections to the local databases are also possible, which increases the potential and the power of this type of system. After three years, DATANET is operational. Nine nodes exist: the central one at JRC Ispra, and local ones at FZK, IRSN, CEA, CIEMAT, FORTUM, AEKI, KTH and GRS. Training weeks are periodically organized at JRC-

Ispra. The results of more than 100 experiments have been implemented so far.

Research priority assessment is also an integrating activity. It identifies research priorities and intends to re-orientate progressively the existing national programmes, to contribute to launch new ones in a coordinated way, eliminating duplications and developing complementarities. This activity was initiated during the second SARNET year, with close collaboration amongst participants (those mainly involved in EURSAFE (Magallon, 2005)), representing Technical Support Organizations (TSO), industry and utilities. As in the Phenomena Identification and Ranking Table (PIRT) carried out in EURSAFE, the whole spectrum of SA situations, extending from core uncovering to long term corium stabilization, long term containment integrity, and fission product release to the environment was considered. The main conclusions from the EURSAFE approach have been confirmed. 21 elementary phenomena are considered as needing further research (note that in some case, a small amount of research work is expected), 7 new or re-oriented issues have been identified. The aim is to periodically update these conclusions taking into account progress in research and of evolution of needs, and to be able to conclude that some issues are closed, meaning that the level of knowledge on these issues is sufficient as regards the uncertainties and their associated impact on a global SA scenario calculation.

4.2 Jointly Executed Research Activities

These activities constitute the R&D basis of the network. In spite of the accomplishments reached in SA research, the assessment of research priorities shows that efforts are still needed on some issues to reduce uncertainties considered important and to consolidate SA management plans. Joint research activities in SARNET are executed to help resolve these remaining issues. They are split into three areas: corium behaviour, containment integrity and source term.

In all three areas, the same method has been adopted: review and selection of available relevant experiments, synthesis of analyses and interpretation of data from these experiments, and model review, synthesis and proposals of new or improved models for ASTEC.

Corium behaviour is a large topic dealing with more than half of the issues selected in the EURSAFE PIRT. The corium area ranges from early phase of core degradation to late phase core degradation and ex-vessel corium stabilization. A major effort is also underway on the development and improvement of the corium thermodynamic and material physical property databases. Joint activities have been deployed, such as the contribution to the definition and the interpretation of OECD-CCI tests around the MCCI programme, with benchmark exercises and associated model improvement, and a contribution to the definition and interpretation of PLINIUS and LACOMERA tests: QUENCH-10 on air ingress in bundle geometry, QUENCH-11 on boil-down and quench, QUENCH-12 with VVER bundle, COMET-L1 and L2 to study MCCI in 2D geometry, LIVE or VULCANO-COMET tests. Similar activities have been carried out for ongoing and new projects from the

International Scientific and Technical Centre (ISTC): PARAMETER project on core top flooding models, METCOR on the impact of thermo-mechanical interaction on the vessel behaviour, CORPHAD on the corium thermodynamic (improvement of the NUCLEA database). In the International Source Term Programme (see Source Term part below), FZK and IRSN have harmonized their test matrices on Zircaloy oxidation by air/steam mixtures and on B4C oxidation and degradation.

The research efforts on energetic phenomena that could potentially threaten containment integrity concern hydrogen behaviour and fast interactions in the containment. For the former, the hydrogen combustion and associated risk mitigation is studied, concentrating on the formation of combustible gas mixtures, local gas composition and potential combustion modes, including reaction kinetics inside catalytic recombiners. Hydrogen distribution within the containment is studied to assess the risk of high concentrations. Experimental programmes on combustion with gradients (ENACCEF) and recombiner kinetics (REKO-3) are ongoing. Benchmarks are ongoing on ENACCEF experimental results, on interaction of sprays with containment atmosphere, on condensation issues and on interactions between Passive Autocatalytic Recombiners (PARs) and containment atmosphere. The PROCO combustion model, improved using the first experimental results, has been transferred to ASTEC and testing are still underway. In ISP-47, data from the TOSQAN, MISTRA and ThAI facilities were used for further validation of lumped-parameter and CFD codes. Limitations of CFD codes (especially commercial codes) were identified with respect to wall condensation modelling and saturation conditions. Specific topics such as mitigation system modelling, sprays and recombiners have been identified as future tasks.

Concerning fast interactions, fuel-coolant interaction is studied to increase the knowledge of parameters affecting steam explosion energetics during corium relocation into water, and determine the risk of vessel or containment failure by investigation of specific processes like premixing, melt fragmentation and particle heat transfer mode. The KROTOS facility is now under operation and a KROTOS-PLINIUS test (K-101) was performed, leading to a limited quantity of melt (300g). This test has been repeated. post-test calculations by various partners are ongoing. In the OECD programme SERENA, reactor case calculations were performed and progress towards synthesis of experiment interpretations achieved. Direct Containment Heating (DCH) processes are studied, including melt dispersion into various reactor compartments, heat transfer and chemical processes such as production and combustion of hydrogen. A DISCO experiment with the geometry of a French reactor was performed in the EC-LACOMERA programme, which was used as a benchmark for lumped parameter code calculations. It has been documented in four reports. A report on LACOMERA-L2 test with VVER-1000 geometry has also been issued.

In the Source Term area, the main safety-related issues addressed are the effect of air ingress, i.e. the influence of an oxidising environment on release and circuit source term phenomena, iodine volatility in the primary circuit,

particularly for silver-indium-cadmium release (as these absorber elements play a significant role in iodine chemistry), containment by-pass in the case of steam generator tube rupture, aerosol retention in containment cracks, aerosol remobilization, and aerosol and iodine behaviour in the containment. These are dealt with in several work packages where technical discussion 'circles' clustering participants around specific issues are highlighted, bringing experimentalists and modellers closer together. The main achievements have been detailed by Haste (2006). A large part of the activity is devoted to the definition / preparation of the so-called International Source Term Programme launched by IRSN, CEA and EDF with the support of the European Commission (Clement, 2005). Concerning Fission Products (notably Ruthenium) release from irradiated fuel under very oxidising conditions, a large effort has been devoted to the interpretation of available AECL and of RUSSET (AEKI) data. It has been concluded that ruthenium release occurs in oxide form after an incubation period during which full oxidation of fuel and cladding occurs. From RUSSET and VTT tests, it has been noticed that oxide forms can stay volatile enough in lower temperature regions to be transported to the reactor containment. It has been emphasized that water vapour likely suppresses decomposition of RuO₄ on stainless steel. This result is of major importance for source term as it shows that depending on conditions, some ruthenium may reach the containment in a stable volatile form. Further data are required (RUSSET, VTT tests and VERDON (CEA)). The conditions in future tests VERDON (Clement, 2005) are being defined by pre-test calculations. In cooperation with the ISTC, the VERONIKA experiment proposal on fission product release from highly irradiated VVER fuel was reviewed and the SARNET team proposed interesting modifications to the test matrix which were taken into consideration; this followed a similar exercise with EVAN.

Concerning Iodine Chemistry in the Circuit IRSN has provided an overall interpretation of iodine chemistry in the circuit. Under reducing conditions, and without absorber material, iodine chemistry seems relatively straightforward, the iodine being transported predominantly as caesium (and rubidium) iodide. In oxidizing conditions the picture is more complicated since Cs take up in forms other than CsI affects iodine chemistry. Hence, iodine can either still be principally CsI or tends to form other metal iodides such as with control rod materials or, if these are not present, conditions become conducive to HI formation. These statements still need to be confirmed. Future CHIP tests will provide useful data for a full understanding. The CHIP programme (Clement, 2005) will provide kinetic and thermodynamic data on iodine transport to primary circuit (RCS) breaks under reactor accident conditions. Two complementary sets of tests are planned, analytical and phenomenological.

Regarding Radioactive Aerosols Issues, three scenarios are being addressed: steam generator tube rupture (SGTR) sequences, remobilisation from RCS deposits and transport of aerosols through containment cracks.

Several facilities have investigated aspects of the aerosol retention within the steam generator under SGTR conditions: PSAERO/HORIZON, PECA/SGTR and ARTIST. PSAERO/HORIZON tests have shown that

resuspension is important in aerosol retention within horizontal tubes and that sudden velocity changes enhance resuspension. The PECA/SGTR tests showed that in the break stage, under all conditions tested, the mass retained was less than 20% of that injected. For flow rates above 100 kg/h, the higher the gas velocity, the lower the total mass depleted on tube surfaces, but at lower flow rates this trend is not maintained. These results were consistent with the small decontamination factors (DFs) measured under similar conditions (dry secondary side) in ARTIST (EU 5th FW SGTR project). New activities concern investigation of physical resuspension using data from the EU/JRC Ispra STORM project.

Revolatilisation tests are being performed in the small-scale REVAP facility where samples from PHEBUS are being tested under different conditions. These tests show that the extent of Cs revaporisation is very high (~95%) on flat metallic substrates. During slow temperature ramping under flowing steam, it starts at 550°C and is rapid until 750°C; it continues to 1000°C but it is practically finished by then. Radiotracer testing confirms that CsOH deposits on stainless steel have the same behaviour as that of the PHEBUS sample deposits. Further tests are needed to achieve a correlation of results.

Retention of aerosols in containment cracks can be effective, particularly in the presence of steam (SIMIBE tests). More data are needed to support the theoretical developments underway.

The experimental facilities involved in Containment Chemistry are: PHEBUS FP, CAIMAN, SISYPHE, the Chalmers facility, PARIS and EPICUR (Clement, 2005).

Waste Management Technology (once part of AEA Technology) is compiling an Iodine Data Book which aims to provide a critical review of the data used in the development and validation of iodine chemistry models. The first part, covering aqueous inorganic iodine radiation chemistry, was produced in the first year of the project. Particular attention is being given to the interpretation of some PHEBUS observations. The CAIMAN programme gave also some interesting results: in the presence of paints, irradiation and high temperature, organic iodide can be the dominant form of volatile iodine; in alkaline conditions, gaseous iodine concentrations decrease by several orders of magnitude. The nature of mass transfer regime between sump and gas has been specifically addressed in SISYPHE. The two main effects of evaporating conditions are to increase the kinetics of transfer from the liquid to the gaseous phase and to change the steady state iodine concentrations, the sump iodine concentration being reduced. The well-known two-film model has been modified to extend it to this type of conditions.

The effect of radiation on the nature of containment atmosphere and the effect of metallic impurities in the sump have been investigated in the PARIS and Chalmers experimental programmes, respectively. The organic iodine formation models are based on a simultaneous consideration of thermal and radiolytic mechanisms both in gas and liquid phases. There are however discrepancies in the aqueous modelling, essentially concerning the organic sources. Data from the EPICUR programme are suitable for validation of these models. To complete the picture, ruthenium behaviour in the containment is now

studied experimentally and theoretically, as well as the effect of fission product heating on passive autocatalytic recombiners, and finally cooperative evaluation of the ThAI-Iod9 integral test is under way.

4.3 Spreading of Excellence Activities

The third major type of activity concerns spreading of excellence. The more experienced organizations have started to contribute diffusing the excellence by preparing an educational course on SA phenomenology addressing PhD students and young researchers, which was given in January 2006, over 5 days. A training course on “Accident progression (data, analysis and uncertainties)”, addressing instead more experienced nuclear safety specialists is scheduled in March 2007, over 5 days. Besides this, the content of a text book on SA phenomenology has been set up. This book covers historical aspects of Light Water Reactor (LWR) safety and principles, phenomena concerning in-vessel accident progression, both early and late containment failure, fission products (FP) release and transport; it contains a description of analysis tools or codes, of management and termination of SA, as well as environmental management. It also gives elements on Generation 3 LWRs. The partners who have agreed to work together in preparing the first course and writing this book are universities, TSOs, national laboratories and industrial organizations that share their great talent and experience within SARNET.

These spreading of excellence activities are complemented by a mobility programme under which students and researchers can go into different laboratories of SARNET for training. For the third SARNET year about twelve delegations have been completed or are underway.

5. SARNET FOLLOW-UP

The current SARNET contract with the EC was defined for a four-year period from April 2004 to March 2008. Then, the idea was to tend to self-sustainability of the network. It is with this main consideration that a SARNET follow-up is currently under preparation, based on the work of a specific working group composed of 9 representatives of the Governing Board.

Nevertheless, in the very near future, in this field of Severe Accidents on NPPs, where no industries are strongly interested in terms of potential direct benefits, the self-sustainability is difficult to reach. So, it is planned to ask again for a EC co-funding, for a certain duration, in the 7th Framework Programme, but with reducing the SARNET perimeter. The general structure would remain as it is, but the Project would be more focused on high-level integrating actions consisting in defining jointly agreed research priorities and in analysing, selecting and promoting R&D programme proposals that would be granted a SARNET label according to the defined priorities.

The other key integrating activities would be pursued: integration of acquired knowledge in ASTEC, work on PSA2 methodologies, spreading the knowledge (public SARNET WEB site and Advanced Communication Tool (ACT), organization of education and training courses, encouragement of exchange of students and researchers, organization of conferences and seminars), etc. The topics should also be extended toward crisis management and

new generations of reactors, in link with the so-called Nuclear Fission Technology Platform.

Beyond the requested funding for the SARNET network, R&D programmes that would be promoted by SARNET would also require EC funding. These programmes would be “satellite” programmes of the Network of Excellence.

6. CONCLUSION

The four-year SARNET Network of Excellence started in April 2004 with the ambitious but highly important objective to provide an appropriate frame for achieving within a couple of years a sustainable integration of the European severe accident research capacities.

By capitalizing the acquired knowledge in the ASTEC code and in the DATANET database, SARNET is really producing conditions necessary for preserving the knowledge produced by thousands of person-years of research, and diffusing it to a large number of end-users. The ASTEC code is being actively used as well as DATANET.

By fostering collaborative work in the PSA2 domain, SARNET has started to create the necessary conditions for harmonizing the approaches and making Europe a leader in SA computer code and risk assessment methodology.

Through an education and training programme (organization of courses, writing a text book addressing young scientists), SARNET is developing synergies with educational institutions to keep attractive this domain of activity for young people. This is reinforced by an efficient mobility programme which allows fruitful exchanges between European laboratories for young students and researchers.

By fostering collaborative R&D work in the domains of corium behaviour, containment integrity and source term, SARNET is progressing to solve remaining outstanding issues and to provide ASTEC with modelling recommendations. Proposals have been elaborated for various ASTEC models and their implementation is under way.

Finally, SARNET is clearly becoming a reference, in terms of research priorities in the field of SA, having impact on national programmes and associated budgets. Progressively all the research activities in this field will become coordinated by the Network, which contributes to an optimised use of European resources.

ACKNOWLEDGMENTS

The authors thank the technical contributors within SARNET organizations, too numerous to name, and the European Commission for funding SARNET, in the 6th Framework Programme area “Nuclear Fission: Safety of Existing Nuclear Installations”, under contract number FI6O-CT-2004-509065.

REFERENCES

- Clément B., Zeyen R., 2005, The Phébus FP and International Source Term Programmes, *Proc. Nuclear Energy for New Europe 2005*, Bled, Slovenia.
- Haste T. et al., 2006, SARNET: Integrating Severe Accident research in Europe: key issues in the Source Term area, *ICAPP 2006*, Reno, Nevada, USA.

Magallon D. et al., 2005, European Expert Network for the Reduction of Uncertainties in Severe Accident Safety Issues (EURSAFE), *Nuclear Engineering and Design*, vol. 235, pp. 309-346.

Micaelli J.C. et al., 2005, SARNET: A European Cooperative Effort on LWR Severe Accident Research, *European Nuclear Conference 2005*, Versailles, France.

Van Dorsselaere J.P., Allelein H.J., Neu K., 2006, Progress and perspectives of ASTEC applications in the European network SARNET, *Proc. EUROSAFE Forum 2006*, Paris, France.